



Most Widely Accepted and Trusted

ICC-ES Listing Report

ICC-ES | (800) 423-6587 | (562) 699-0543 | www.icc-es.org

ESL-1021

Reissued 06/2018

This listing is subject to renewal 06/2019.

DIVISION: 09 00 00—FINISHES

SECTION: 09 00 00—FINISHES

REPORT HOLDER:

CHEMCO, INC.

EVALUATION SUBJECT:

**FRX, SAFERWOOD AND THERMEX-FR FIRE-RETARDANT-TREATED
WOOD PRODUCTS**



Look for the trusted marks of Conformity!

“2014 Recipient of Prestigious Western States Seismic Policy Council (WSSPC) Award in Excellence”



A Subsidiary of

ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.



ICC-ES Listing Report

ESL-1021

Reissued June 2018

This listing is subject to renewal June 2019.

www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

CSI: DIVISION: 09 00 00—FINISHES
Section: 09 00 00—Finishes

Product Listing:

The ICC-ES product-certification system includes evaluating reports of tests of standard manufactured product, prepared by accredited testing laboratories and provided by the listee, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the listee's quality system.

Products: FRX, SAFERWOOD AND THERMEX-FR FIRE-RETARDANT-TREATED WOOD PRODUCTS

Listee: CHEMCO, INC.

Evaluation: Chemco, Inc., FRX, SaferWood and Thermex-FR fire-retardant treated wood were evaluated when tested to the following standard:

- CAN/ULC- S102-10, Standard Method of Test for Surface Burning Characteristics of Building Materials and Assemblies, Underwriters Laboratories of Canada.

Findings: Chemco, Inc., FRX, SaferWood and Thermex-FR fire-retardant treated wood have a flame spread rating of 25 or less and a smoke developed classification of 100 or less.

Identification:

1. Lumber and plywood treated with FRX, SaferWood and Thermex-FR fire-retardant chemicals are identified with a label indicating the listee's name (Chemco, Inc.) and address, the product name, the species of the wood treated, the ICC-ES listing report number (ESL-1021) and the ICC-ES listing mark.
2. The report holder's contact information is the following:

CHEMCO, INC.
POST OFFICE BOX 875
FERNDALE, WASHINGTON 98248
(360) 366-3500
www.chemco.org
www.saferwood.com
Info@chemco.org

Installation: The product must be installed in accordance with the Chemco, Inc., instructions.

Models: Structural Grade Southern Pine Lumber, Douglas Fir Lumber, White Spruce Lumber, Western Red Cedar Lumber, Western Hem-fir Lumber, Southern Pine Plywood, Douglas fir Plywood, White Spruce Plywood, Western Red Cedar Plywood and Western Hem-fir Plywood.

Conditions of listing:

1. The listing report addresses only those findings noted above and is applicable to the flame spread rating and smoke developed classification only.
2. Approval is the sole responsibility of the local code official.
3. This listing report applies only to the materials tested and as submitted for review by ICC-ES.
4. FRX, SaferWood and Thermex-FR lumber and plywood are treated in Ferndale, Washington, under a quality control program with inspections by ICC-ES and Fire Tech Services, Inc. (AA-641).

Listings are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the listing or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this listing, or as to any product covered by the listing.