



Most Widely Accepted and Trusted

# ICC-ES Listing

## ESL-1021

ICC-ES | (800) 423-6587 | (562) 699-0543 | www.icc-es.org

Issued 06/2015

This listing is subject to renewal 06/2016.

**DIVISION: 09 00 00—FINISHES**

**SECTION: 09 00 00—FINISHES**

**REPORT HOLDER:**

**CHEMCO, INC.**

**POST OFFICE BOX 875  
FERNDALE, WASHINGTON 98248**

**EVALUATION SUBJECT:**

**FRX, SAFERWOOD AND THERMEX-FR FIRE-RETARDANT-TREATED  
WOOD PRODUCTS**



Look for the trusted marks of Conformity!

*“2014 Recipient of Prestigious Western States Seismic Policy Council (WSSPC) Award in Excellence”*



A Subsidiary of

*ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.*



**ICC-ES Listing****ESL-1021**

Issued June 2015

*This listing is subject to renewal June 2016.*[www.icc-es.org](http://www.icc-es.org) | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

**CSI:** DIVISION: 09 00 00—FINISHES  
Section: 09 00 00—Finishes**Product Listing:**

The ICC-ES product listing includes testing samples taken from the market or supplier's stock, or a combination of both, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the listee's quality system.

**Products:** FRX, SAFERWOOD AND THERMEX-FR FIRE-RETARDANT-TREATED WOOD PRODUCTS**Listee:** CHEMCO, INC.  
POST OFFICE BOX 875  
FERNDALE, WASHINGTON 98248  
(360) 366-3500**Evaluation:** Chemco, Inc., FRX, SaferWood and Thermex-FR fire-retardant treated wood, was evaluated when tested to CAN/ULC- S102-10, Standard Method of Test for Surface Burning Characteristics of Building Materials and Assemblies.**Findings:** Chemco, Inc., FRX, SaferWood and Thermex-FR fire-retardant treated wood has a flame spread rating of 25 or less and a smoke developed classification of 100 or less.**Identification:** Lumber and plywood treated with FRX, SaferWood and Thermex-FR fire-retardant chemicals are identified with a label indicating the listee's name (Chemco, Inc.) and address, the product name, the species of the wood treated and the listing number (ESL-1021).**Installation:** The product must be installed in accordance with the Chemco, Inc., instructions.**Models:** Structural Grade Southern Pine Lumber, Douglas Fir Lumber, White Spruce Lumber, Western Red Cedar Lumber, Western Hem-fir Lumber, Southern Pine Plywood, Douglas fir Plywood, White Spruce Plywood, Western Red Cedar Plywood and Western Hem-fir Plywood.**Conditions of listing:**

1. The listing addresses only those findings noted above and is applicable to the flame spread rating and smoke developed classification only.
2. Approval is the sole responsibility of the local code official.
3. This listing applies only to the materials tested and as submitted for review by ICC-ES.
4. FRX, SaferWood and Thermex-FR lumber and plywood are treated in Ferndale, Washington, under a quality control program with inspections by ICC-ES and Fire Tech Services, Inc. (AA-641).